

**We offers Custom and Economical Solutions to a wide range of industries
and service segments**



**Energy
Management**



**Process
Control**



**Industrial
Automation**



**Building
Management**



**Solar
Monitoring**



**Test &
Measurement**



K-Lite

Application

OVERVIEW



Alarms

- Pop-Up
- Audio
- e-Mail
- SMS



SMS

- Real-time Data
- Historical Data
- Custom Formats
- Multiple Recipients



Monitor

- Electricity
- Water
- Gas
- Temperature
- Flow
- Pressure
- Levels
- Status

Analysis



- Historical Data
Graphs | Readings
- Dashboards
- Alarms

Reports



- Excel Format
Graphs | Dashboards |
Readings
- Custom Templates



AREAS



Industries


- Electricity.
EB | DG | Machines | Chillers | Boilers |
Breakers | Relays | etc.
- Production / Generation.
- Equipment Run hours.
- Power Interruptions.
- Diesel Levels.
- Temperature.
- Pressure.

Buildings

- Electricity.
EB | DG | UPS | Lighting | HVAC | etc.
 - Temperature.
 - Water Consumption.
-
- ⇒ Commercial Buildings
 - ⇒ Hotels
 - ⇒ Textiles
 - ⇒ Apartments

Data Centers

- Electricity.
EB | DG | UPS | Lighting | HVAC | PDU | Racks |
etc.
- Server Details.
- Temperature.
- PUE (Power Usage Effectiveness)



SOFTWARE FEATURES



ARCHITECTURE

- Server & Client architecture.
- All configurations, features in both server & clients.
- Independent customisation in both server & clients.



REALTIME MONITORING

- Creation of own matrix screens.
- Devices & Parameters selection as per user needs.
- Easy selection of parameters by Drag & Drop.
- Formats
Tabular | Filter based |
Device wise | Mimics | Graphs
- Device communication status.



ALERTS

- User configurable.
- Indication
Pop-up | Audio | e-Mail | SMS
- Alarms Analysis.



HISTORICAL ANALYSIS

- Tables.
- graphs.
- Easy selection of parameters by Drag & Drop.
- Parameters Grouping for quick access.
- Export Data.
- Print Graphs.
- SMS.

SOFTWARE FEATURES



DASH BOARDS

- Custom Dashboards.
- Energy Dashboard.
- Gadgets & Layouts selection.
- Devices & Parameters selection as per user needs.
- Formats
 - Bar | Line | Area | Pie | Doughnut
- Intervals
 - Daily | Weekly | Monthly | Yearly



REPORTS

- Custom groups creation.
- Defining own time slots.
- Formats
 - Periodic | Daily | Weekly | Monthly | Yearly | Min Max | Zone Wise | Till Date | Dashboards.
- Manual Entries.
- Auto report generation.
- Auto e-Mail of Reports.
- Custom reports as per user needs.



CONFIGURATIONS

- Devices.
- Ports.
- Custom devices.
- Data logging .
- OPC server & client.
- Users.



MISCELLANEOUS

- Parameters availability even in case of non availability of the same in field devices.
- Integral calculations of Real time data.

ENERGY MANAGEMENT SYSTEM BENIFITS

BENCH MARKING ENERGY CONSUMPTION

- Understanding all forms of energy use and other utilities is the first step in assessing the potential for efficiency savings.
- K-Lite software can guide, plan, manage, organise and display key energy and other parameters in real time.
- It provides a tremendous diagnostic tool for identifying and solving energy problems and appreciating opportunities for cost savings.

REDUCTION IN SPECIFIC ENERGY CONSUMPTION

- The majority of energy consumption in the plant is for production activity.
- Each product measured will be measured by energy consumed to make one unit of product.
- With K-Lite software, the plant manager can measure as well as reduce energy consumption by close monitoring of machinery run hours and prevent idle running machine.

REDUCTION IN DISTRIBUTION LOSS

- The power received from electricity board and captive power is being fed through various transformers to various load centres like MCC, PCC, pumps, blowers, compressors, chillers, lighting loads and etc.
- It is very important to know whether the power received from the source is being utilized effectively by all machines and the level of the loss incurred due to distribution. With the help of K-Lite software, by understanding the measured values, various steps can be taken to reduce losses.

REDUCE PEAK DEMAND

- K-Lite software can assist in reducing peak demand and associated demand charges.
- Regular verification of daily load profile will help plant manager to identify and eliminate demand spikes, such as those associated with simultaneous motor, pump, compressor start-ups or schedule operation in such a way as to reduce overall demand.

ENERGY RESOURCE PLANNING

- K-Lite software computes the energy balance at various feeder and system losses to formulate and implement loss elimination schemes as any electrical distribution network has inherent losses.
- Since energy use pattern of every feeder is monitored, any variation in power consumption pattern at any process or sub section is exposed immediately for immediate control.


ELIMINATING INEFFICIENT EQUIPEMENT OPERATION

- K-Lite software is highly useful in quickly spotting wasteful energy use.
- By reviewing daily load profiles and comparing to benchmark labels, plant manager can identify the instance when equipment is not performing properly or unused equipment is left running.
- This will help customer in saving of 5% or more just from eliminating gross wastage.






MEASUREMENT AND VERIFICATION

- K-Lite software measures and records energy consumption trends. Verifies results of energy saving measures taken. Enables achievement of objectives with the precision which assist in decision making.

ARCHITECTURE



SAMPLE SCREENS



DASHBOARDS

ENERGY DASHBOARD

- Plant Total Load Monitoring.
- Historical Graphs. Grouping for easy access.
- Display of Top Users.



CUSTOM DASHBOARDS


- Creation of Dashboards.
- Layouts and gadgets selection.
- Devices and parameters selection.



DASHBOARDS


SCREENS

- Creation of Screens.
- Layout Selection.




GADGETS

- Creation of Gadgets.
- Gadgets Details Selection.




PARAMETERS

- Devices Selection.
- Parameters Selection.




DASHBOARDS


4 GADGETS – LAYOUT2




4 GADGETS – LAYOUT3




3 GADGETS – LAYOUT1




3 GADGETS – LAYOUT2



2 GADGETS – LAYOUT1



2 GADGETS – LAYOUT2



REAL TIME DATA

TABLE FORMAT

- Screen Creation.
- Devices & Parameters selection as per user needs.
- Transpose view.

Online Data Analysis

Company Logo Company Name CompanyLocation

Energy Management System San D Automation Pvt Ltd

Mon, Mar 07, 2016 4:05:37 PM

Screen Name : Screen1


Screen

Tabular View Filter Based Device Wise Energy Mimic

Sno	Device	kW (Total)	Amp (Avg)	Vll (Avg)	Vln (Avg)	kVA (Total)	kVAR (Total)	PF (Avg)	Frequency	kWh (Imp)	kVAh (Imp)	kVARh (Imp-I)	THD (Vll) (Rph)	THD (Vll) (Yph)	THD (Vll) (Bph)	THD (Amp) (Rph)	THD (Y) (Y)
1	Device1	751.19	1091.94	412.78	238.32	780.54	191.82	0.962	49.97	1511807.2	1623416.4	426402.2	2.84	3.88	2.16	12.27	10
2	Device2	215.23	554.53	407.30	235.12	390.97	323.46	0.550	49.96	1270087.9	1487654.3	315368.1	2.19	2.34	2.34	-999.00	-99
3	Device3	24.90	42.60	412.08	237.91	30.38	17.26	0.820	49.97	51233.4	58927.8	27411.1	2.67	3.72	1.96	-999.00	-99
4	Device4	20.17	28.52	412.07	237.91	20.35	-1.96	-0.991	49.96	12853.9	12993.5	0.3	2.87	3.75	1.87	8.82	10
5	Device5	60.27	87.12	411.76	237.73	62.10	14.52	0.970	49.96	105716.9	108233.3	20723.0	2.82	3.84	1.84	8.41	4
6	Device6	26.88	41.88	412.00	237.87	29.79	12.55	0.902	49.96	71466.4	81061.7	34228.3	2.71	3.79	1.95	10.15	5
7	Device7	79.26	177.50	411.87	237.79	85.59	-31.67	-0.926	49.95	179123.7	197026.5	0.7	2.80	3.91	1.98	6.40	4
8	Device8	222.79	360.34	411.56	237.61	256.77	123.62	0.868	49.95	274834.3	322438.8	159325.2	2.78	3.73	2.19	12.59	11
9	Device9	192.45	377.24	410.24	236.76	267.73	-144.68	-0.719	49.95	334782.8	484170.1	80903.3	3.42	5.10	4.39	42.44	41
10	Device12	101.96	154.81	398.81	230.26	106.88	29.95	0.954	49.96	184904.1	192608.5	50442.3	2.33	2.41	2.55	10.88	7
11	Device13	55.29	94.19	407.11	235.05	66.40	35.97	0.833	49.97	366658.6	448848.2	244680.1	6.19	3.77	2.39	6.11	6
12	Device14	0.00	0.00	404.81	233.76	0.00	0.00	0.000	49.97	419079.2	546388.4	187113.1	2.39	2.26	2.44	-999.00	-99
13	Device15	47.69	358.55	410.78	237.53	254.79	-49.92	-0.187	49.97	65819.6	87212.2	4613.0	7.08	7.98	7.16	353.66	29
14	Device16	502.32	1204.82	395.81	228.69	826.59	652.98	0.608	49.96	2203092.2	3477926.1	2431436.3	7.07	8.99	7.89	5.31	6
15	Device17	1133.58	1794.03	408.86	236.16	1270.43	463.23	0.892	49.96	832570.9	1033143.8	514100.8	9.68	16.43	8.31	25.20	33
16	Device18	326.83	540.85	407.01	235.37	381.34	191.98	0.857	49.96	204273.2	242666.0	130149.4	5.17	5.39	5.09	3.57	4
17	Device20	0.00	0.00	0.00	0.00	0.00	0.00	0.000	0.00	1091017.6	1177334.8	366828.0	0.00	0.00	0.00	0.00	0
18	Device21	54.62	93.40	411.75	237.73	66.57	37.29	0.821	49.97	253463.2	332293.9	205925.8	2.07	2.27	2.52	2.98	5
19	Device22	187.10	294.16	411.79	237.75	209.79	91.12	0.892	49.97	148514.5	168964.2	72654.6	2.25	2.49	2.97	8.46	7
20	Device23	584.43	856.01	413.66	238.83	612.86	179.80	0.954	49.97	739183.0	769918.7	209046.1	2.36	2.19	2.55	2.61	3
21	Device24	265.22	415.84	414.28	239.19	298.39	132.89	0.889	49.97	294577.2	341136.9	167433.3	2.15	2.36	2.30	-999.00	-99

GRAPHS


- Parameters selection by Drag & Drop.
- Modification of Trend Properties, Scales.
- Grouping of parameters for easy access.



REAL TIME DATA


SCREENS

- Defining Screens.
- Defining Groups/Sections.




DEVICES

- Devices Selection.
- Multiple devices selection at a time.



PARAMETERS


- Parameters Selection.
- Multiple parameters selection at a time.



REAL TIME DATA



ENERGY MIMICS

- All phase wise parameters display.
- Import, Export, THD, Demand parameters display.
- Representation in dial controls.



BREAKERS MIMICS


- Status monitoring.
- Control breaker remotely.
- Measurement parameters display.
- Trip history.



REAL TIME DATA


SINGLE LINE DIAGRAM

- SLDs as per user plant architecture.
- Custom screens as per user needs.



CATEGORY WISE


- Category wise screens as per user needs.



SYSTEM SCREENS

DATA CENTER

- Physical layout representation.
- Load details as per the layout.





HISTORICAL DATA

TABLE FORMAT

- Parameters selection by Drag & Drop.
- Date & Time, Interval selection.
- Grouping of parameters for easy access.
- Export Data.

GRAPHS

- Parameters selection by Drag & Drop.
- Date & Time, Interval selection.
- Grouping of parameters for easy access.
- Modification of Trend Properties, Scales.
- Cursors creation.
- Export Data.
- Print Graphs.
- Zoom in & out.



ALARMS

ALARMS CREATION

- Define alarms.
- Set & modify alarm limits up to 4 levels.
- Alarms indication selection (Popup, Audio, e-Mail, SMS).

Alarm Details Entry

Alarm Details Entry

Sno	Devices	Parameters
1	Device1	KVA (Total)
2	Device2	KW (Total)
3	Device3	KVAR (Total)
4	Device4	PF (Avg)
5	Device5	VII (Avg)
6	Device6	VIn (Avg)
7	Device7	Amp (Avg)
8	Device8	Frequency
9	Device9	KVA (Rph)
10	Device10	KW (Rph)
11	Device11	KVAR (Rph)
12	Device12	PF (Rph)
13	Device13	VII (Rph-Yph)
14	Device14	VIn (Rph-N)
15	Device15	Amp (Rph)
16	Device16	KVA (Yph)
17	Device17	KW (Yph)
18	Device18	KVAR (Yph)
19	Device19	PF (Yph)
20	Device20	VII (Yph to 8ph)
21	Device21	VIn (Yph to N)
22	Device22	Amp (Yph)

Alarm Name: Alarm1
Device: Device1
Parameter: Amp (Avg)
Low: 160 High: 170
Use 2nd Level Limits: ☒
Very Low: 150 Very High: 180
Status: Enable
Description:
Pop-up Message? ☒
Audio? ☒ Audio Freq: 1500 Hz Audio Duration: 1000 ms
E-Mail? ☒
SMS? ☒ SMS Group: Group1
OK Cancel

ALARMS ANALYSIS

- View generated alarms.
- Acknowledge alarms.
- Date & Time selection.

Alarm Analysis

Company Logo Company Name Energy Management System SAN D Automation Pvt Ltd

Start Time: 10:34:35 PM 28/04/2014 End Time: 10:34:35 PM 29/04/2014 Filter: Un Acknowledged Acknowledge

Sl No	Date & Time	Alarm Name	State	Duration	State Description	Status	Description
17	04/29/2014 17:35:20	Alarm4	High	23.24 Sec	Changed from Good to High	Un Acknowledge	
18	04/29/2014 17:31:24	Alarm4	High	2.73 Min	Changed from High.High to High	Un Acknowledge	
19	04/29/2014 17:27:43	Alarm4	High.High	3.63 Min	Changed from High to High.High	Un Acknowledge	
20	04/29/2014 17:26:58	Alarm4	High	42.96 Sec	Changed from High.High to High	Un Acknowledge	
21	04/29/2014 17:25:40	Alarm4	High.High	1.25 Min	Changed from High to High.High	Un Acknowledge	
22	04/29/2014 17:23:44	Alarm4	High	1.91 Min	Changed from High.High to High	Un Acknowledge	
23	04/29/2014 17:23:41	Alarm5	High	29.64 Min	Changed from Good to High	Un Acknowledge	
24	04/29/2014 17:22:32	Alarm5	High	43.15 Sec	Changed from Good to High	Un Acknowledge	
25	04/29/2014 17:22:10	Alarm4	High.High	1.52 Min	Changed from High to High.High	Un Acknowledge	
26	04/29/2014 17:21:44	Alarm4	High	22.73 Sec	Changed from High.High to High	Un Acknowledge	
27	04/29/2014 17:20:59	Alarm4	High.High	42.87 Sec	Changed from High to High.High	Un Acknowledge	
28	04/29/2014 17:20:34	Alarm4	High	22.93 Sec	Changed from High.High to High	Un Acknowledge	
29	04/29/2014 17:17:51	Alarm4	High.High	2.67 Min	Changed from High to High.High	Un Acknowledge	
30	04/29/2014 17:16:16	Alarm4	High	1.53 Min	Changed from High.High to High	Un Acknowledge	
31	04/29/2014 17:15:53	Alarm4	High.High	20.24 Sec	Changed from High to High.High	Un Acknowledge	
32	04/29/2014 17:14:44	Alarm4	High	1.11 Min	Changed from High.High to High	Un Acknowledge	
33	04/29/2014 17:12:44	Alarm3	High.High	40.58 Min	Changed from High to High.High	Un Acknowledge	
34	04/29/2014 17:12:21	Alarm3	High	20.29 Sec	Changed from High.High to High	Un Acknowledge	
35	04/29/2014 17:10:44	Alarm3	High.High	1.58 Min	Changed from High to High.High	Un Acknowledge	
36	04/29/2014 17:10:21	Alarm3	High	20.17 Sec	Changed from High.High to High	Un Acknowledge	
37	04/29/2014 17:09:35	Alarm3	High.High	43.29 Sec	Changed from Low.Low to High.High	Un Acknowledge	
38	04/29/2014 17:09:10	Alarm2	High.High	43.73 Min	Changed from Low.Low to High.High	Un Acknowledge	
39	04/29/2014 17:09:10	Alarm3	Low.Low	22.67 Sec	Changed from High.High to Low.Low	Un Acknowledge	
40	04/29/2014 17:09:10	Alarm2	Low.Low	22.59 Sec	Changed from High.High to Low.Low	Un Acknowledge	
41	04/29/2014 16:59:24	Alarm4	High.High	15.30 Min	Changed from High to High.High	Un Acknowledge	
42	04/29/2014 16:57:49	Alarm4	High	1.53 Min	Changed from Good to High	Un Acknowledge	
43	04/29/2014 16:45:40	Alarm4	High	3.07 Min	Changed from Good to High	Un Acknowledge	
44	04/29/2014 16:41:17	Alarm5	High	38.43 Min	Changed from Low to High	Un Acknowledge	
45	04/29/2014 16:33:36	Alarm5	Low	7.65 Min	Changed from High to Low	Un Acknowledge	
46	04/29/2014 16:31:40	Alarm4	High	1.54 Min	Changed from Good to High	Un Acknowledge	
47	04/29/2014 16:20:34	Alarm4	High.High	1.49 Min	Changed from High to High.High	Un Acknowledge	
48	04/29/2014 16:20:00	Alarm4	High	31.60 Sec	Changed from High.High to High	Un Acknowledge	
49	04/29/2014 16:13:21	Alarm4	High.High	6.61 Min	Changed from High to High.High	Un Acknowledge	
50	04/29/2014 16:09:58	Alarm4	High	3.34 Min	Changed from Good to High	Un Acknowledge	
51	04/29/2014 16:09:49	Alarm5	High	23.73 Min	Changed from Low to High	Un Acknowledge	
52	04/29/2014 15:53:44	Alarm5	Low	16.05 Min	Changed from Good to Low	Un Acknowledge	
53	04/29/2014 15:51:17	Alarm4	High	13.77 Min	Changed from High.High to High	Un Acknowledge	

Note: Hold ctrl key to select or unselect multiple items

MISCE

DEVICE COMMUNICATION STATUS

- Devices communication status display.
- Filter devices by ports.
- Communication statistics display.

Device Commn Status						
Device Communication Status						
SL No	Device Name	Device Type	Port Name	Address	Unit ID	Status
1	Device1	Schneider PM 200	Port1	10.179.60.46	3	Communicating..
2	Device2	Schneider PM 200	Port1	10.179.60.46	4	Communicating..
3	Device3	Schneider PM 200 Test	Port1	10.179.60.46	5	Communicating..
4	Device4	Schneider PM 200 Test	Port1	10.179.60.46	6	Communicating..
5	Device5	Schneider PM 200 Test	Port1	10.179.60.46	7	Communicating..
6	Device6	Schneider PM 200 Test	Port1	10.179.60.46	8	Communicating..
7	Device7	Schneider PM 200	Port1	10.179.60.46	9	Communicating..
8	Device8	Schneider PM 200	Port1	10.179.60.46	10	Communicating..
9	Device9	Schneider EM 6400 Power Ma	Port1	10.179.60.46	110	Commun Failure.
10	Device10	Schneider PM 200	Port1	10.179.60.46	12	Communicating..
11	Device11	Schneider PM 200	Port1	10.179.60.46	13	Communicating..
12	Device12	Schneider PM 200	Port1	10.179.60.46	14	Communicating..
13	Device13	Schneider PM 200	Port1	10.179.60.46	15	Communicating..
14	Device14	Schneider PM 200	Port1	10.179.60.46	16	Communicating..
15	Device15	Schneider PM 800	Port1	10.179.60.46	17	Communicating..
16	Device16	Schneider PM 200	Port1	10.179.60.46	18	Communicating..
17	Device17	Schneider PM 200	Port1	10.179.60.46	19	Communicating..
18	Device18	Schneider PM 200	Port1	10.179.60.46	20	Communicating..
19	Device19	Schneider PM 800	Port1	10.179.60.46	21	Communicating..
20	Device20	Schneider PM 200	Port1	10.179.60.46	22	Communicating..
21	Device21	Schneider PM 200	Port1	10.179.60.46	23	Communicating..
22	Device22	Schneider PM 200	Port1	10.179.60.46	24	Communicating..
23	Device23	Schneider PM 200	Port1	10.179.60.46	25	Communicating..
24	Device24	Schneider PM 200	Port1	10.179.60.46	26	Commun Failure.
25	Device25	Schneider PM 200	Port1	10.179.60.46	27	Communicating..
26	Device26	Schneider PM 200	Port1	10.179.60.46	28	Communicating..
27	Device27	Schneider PM 200	Port1	10.179.60.46	29	Communicating..
28	Device28	Schneider PM 200	Port1	10.179.60.46	30	Communicating..
29	Device29	Schneider PM 200	Port1	10.179.60.46	31	Communicating..
30	Device30	Schneider PM 200	Port1	10.179.60.46	32	Communicating..
31	Device31	Schneider PM 200	Port2	10.179.60.48	3	Communicating..
32	Device32	Schneider PM 200	Port2	10.179.60.48	4	Commun Failure.
33	Device33	Schneider PM 200	Port2	10.179.60.48	5	Communicating..
34	Device34	Schneider PM 200	Port2	10.179.60.48	6	Communicating..
35	Device35	Schneider PM 200	Port2	10.179.60.48	7	Communicating..
Total : 123 Devices 123 Enabled 117 Commn 6 No Commn Sub Total : 123 Devices 123 Enabled 117 Commn 6 No Commn						

MANUAL ENTRIES

- Manual entries on daily basis.
- Integrated parameters can be entered as reading / cumulative value.

Manual Entries Configuration				
Manual Entries				
12/01/2014		Integrated Parameter Value Type Cumulative		
Available Parameters	SL No	Device Name	Value	Value Type
Active Power - avg(kW)	1	Feeder1	0.0	Cumulative
Apparent Power - avg(kVA)	2	Feeder2	0.0	Cumulative
Avg Current(A)	3	Feeder3	0.0	Cumulative
Avg PF	4	Feeder4	0.0	Cumulative
Bphase Current %THD	5	Feeder5	0.0	Cumulative
Bphase Voltage %THD	6	Feeder6	0.0	Cumulative
Forward Active Energy(kWh)	7	Feeder7	0.0	Cumulative
Forward Apparent Energy(kVAh)	8	Feeder8	0.0	Cumulative
Forward Reactive Capacitance Energy(kVARh)	9	Feeder9	0.0	Cumulative
Forward Reactive Inductive Energy(kVARh)	10	Feeder10	0.0	Cumulative
Forward Run Hours(RH)	11	Feeder11	0.0	Cumulative
Frequency(Hz)	12	Feeder12	0.0	Cumulative
L-L avg Voltage(V)	13	Feeder13	0.0	Cumulative
L-N Voltage(V)	14	Feeder14	0.0	Cumulative
Reactive Power -avg(KVAR)	15	Feeder15	0.0	Cumulative
Rphase Current %THD	16	Feeder16	0.0	Cumulative
Rphase Voltage %THD	17	Feeder17	0.0	Cumulative
Yphase Current %THD	18	Feeder18	0.0	Cumulative
Yphase Voltage %THD	19	Feeder19	0.0	Cumulative
	20	Feeder20	0.0	Cumulative
	21	Feeder21	0.0	Cumulative
	22	Feeder22	0.0	Cumulative
	23	Feeder23	0.0	Cumulative
	24	Feeder24	0.0	Cumulative
	25	Feeder25	0.0	Cumulative
	26	Feeder26	0.0	Cumulative
	27	Feeder27	0.0	Cumulative
	28	Feeder28	0.0	Cumulative
	29	Feeder29	0.0	Cumulative
	30	Feeder30	0.0	Cumulative
	31	Feeder31	0.0	Cumulative
	32	Feeder32	0.0	Cumulative
Save Cancel				

DEVICES CONFIGURATION

CONFIGURATIONS

- Define Modbus, BACnet, Opc, Custom devices.
- Multiple devices creation by duplicating.
- Data logging configuration.

DEVICE DETAILS ENTRY

- Device name entry.
- Selection of device make & model, interface details.
- Enable and disable devices.

Devices Configuration

Company Logo Company Name Energy Management System San D Automation Pvt Ltd

Company Location

Devices Configuration

New Duplicate Remove Custom Response Real Time Summary Status

Devices Added: 52
Devices Left: 48

SI No	Device Name	Device Type	Port Name	Port Address	Device Address	Response
1	Device1	Schneider PM 200	Port1	192.168.10.26	3	Default
2	Device2	Schneider PM 700	Port1	192.168.10.26	4	Default
3	Device3	Schneider PM 800	Port1	192.168.10.26	5	Default
4	Device4	Schneider PM 5500	Port1	192.168.10.26	6	Default
5	Device5	Schneider PM 7200	Port1	192.168.10.26	7	Default
6	Device6	Schneider PM 1200	Port1	192.168.10.26	8	Default
7	Device7	Schneider EM 6400	Port1	192.168.10.26	9	Default
8	Device8	Schneider EM 6436	Port1	192.168.10.26	10	Default
9	Device9	Schneider EM 6433	Port1	192.168.10.26	11	Default
10	Device10	Schneider EM 1200	Port1	192.168.10.26	12	Default
11	Device11	Schneider EM 3000	Port1	192.168.10.26	13	Default
12	Device12	Schneider BCPM	Port2	192.168.10.27	1	Default
13	Device13	Elmeasure TM Series	Port3	192.168.10.28	2	Default
14	Device14	Elmeasure LG Series	Port3	192.168.10.28	3	Default
15	Device15	Secure Premier	Port3	192.168.10.28	4	Default
16	Device16	Secure Elite Entity	Port3	192.168.10.28	5	Default
17	Device17	Socomec DIRIS A40	Port3	192.168.10.28	6	Default
18	Device18	Selec MFM 384	Port3	192.168.10.28	7	Default
19	Device19	Satec PM 172	Port3	192.168.10.28	8	Default
20	Device20	L&T Quasar	Port3	192.168.10.28	9	Default
21	Device21	L&T ER 300N	Port3	192.168.10.28	10	Default
22	Device22	Circutor CVM 96	Port3	192.168.10.28	1	Default
23	Device23	GE PQM	Port3	192.168.10.28	21	Default
24	Device24	Masibus Scanner	Port4	192.168.10.29	22	Default
25	Device25	Rishab EM 3400	Port4	192.168.10.29	23	Default
26	Device26	Rishab RM 3400	Port4	192.168.10.29	24	Default
27	Device27	Rishab EM DC	Port4	192.168.10.29	25	Default
28	Device28	Onicon BTU	Port4	192.168.10.29	26	Default
29	Device29	Flow Meter	Port5	192.168.10.30	27	Default
30	Device30	Level Sensor	Port5	192.168.10.30	1	Default
31	Device31	Pressure Sensor	Port5	192.168.10.30	16	Default
32	Device32	Temperature Sensor	Port5	192.168.10.30	17	Default
33	Device33	PLC	Port6	192.168.10.31	1	Default
34	Device34	Breaker	Port7	192.168.10.32	32	Default
35	Device35	Relay	Port7	192.168.10.32	33	Default
36	Device36	Chiller	Port8	192.168.10.33	34	Default
37	Device37	ICD Energen	Port9	192.168.10.34	10	Default
38	Device38	Schneider PM 1200	Port1	192.168.10.26	11	Default

Device Details Entry

Device Details

Device Name: Device1

Type: Real Protocol: Modbus

Port Name: Port1 Response Settings: Default

Device Type: Circutor CVM 96

Status: Enable

Address: 10

Description:

Device Image: Circutor CVM 96.png

OK Cancel

✓ Circutor CVM 96
Circutor CVM 96 Default
Elmeasure LG Series
Elmeasure TM Series
L&T ER 300N
L&T Quasar
Masibus Scanner 8500
Satec PM 172
Schneider EM 1200
Schneider EM 3000
Schneider EM 6400
Schneider EM 6400 Power Max
Schneider EM 6400 with Thd
Schneider EM 6400NG
Schneider EM 6433
Schneider EM 6434
Schneider EM 6436
Schneider EM 6436 Default
Schneider EM 6436 SWPD
Schneider EM 7200
Schneider iEM 3150
Schneider iEM 3155
Schneider PM 1200

REPORTS

REPORT GENERATION

- Report type, Date & Time, Interval selection.
- Defining different time slots.
- Auto reports scheduling.

The screenshot shows the 'Report Generation' window. At the top, it displays 'Company Name' and 'Company Location'. The main header is 'Energy Management System' by 'San D Automation Pvt Ltd'. The date and time are 'Mon, Mar 07, 2016 7:20:36 PM'. Below the header, there are tabs for 'Groups', 'E-Mail', 'Manual', and 'Auto Report'. The 'Groups' tab is active, showing a 'Select Group' dropdown with 'Default' selected. To the right, there are 'Report Type' options: 'Periodic Report' (checked), 'Daily Report', 'Weekly Report', 'Monthly Report', and 'Yearly Report'. Below these are 'Start Date' (03/07/2016) and 'End Date' (03/08/2016) fields. A 'New' button and a 'Remove' button are present. A table lists time slots with columns 'SL No', 'Zone Name', 'Start Time', and 'End Time'. The table contains four rows: 1. Shift-1 (07:00:00 to 18:00:00), 2. Shift-2 (18:00:00 to 23:00:00), 3. Shift-3 (23:00:00 to 07:00:00), and 4. Peak Time (08:00:00 to 18:00:00). To the right of the table, there are options for 'Instantaneous Parameters', 'Calculation Type' (Average), 'Time Stamp Location' (Column Wise), and a 'Separate Sheet for Each Parameter' checkbox. At the bottom, there is a 'Reports Storage Path' field and a 'Generate' button.

SL No	Zone Name	Start Time	End Time
1	Shift-1	07:00:00 (Same Day)	18:00:00 (Same Day)
2	Shift-2	18:00:00 (Same Day)	23:00:00 (Same Day)
3	Shift-3	23:00:00 (Same Day)	07:00:00 (Next Day)
4	Peak Time	08:00:00 (Same Day)	18:00:00 (Same Day)

GROUPS CREATION

- Define groups.
- Devices and parameters selection.

The screenshot shows the 'Report Groups Configuration' window. It has a 'New' button and a 'Remove' button. Below these are 'Groups' and 'Parameters' tabs. The 'Groups' tab is active, showing a list of groups: 'Default', 'Group1', and 'Group2'. The 'Parameters' tab is also visible, showing a list of parameters: 'Amp (Avg)', 'Frequency', 'kVA (Total)', 'kVAh (Exp)', 'kVAh (Imp)', 'kVAR (Total)', 'kVARh (Imp-I)', 'kW (Total)', 'kWh (Imp)', 'kWh (Exp)', 'LDM (kVA)', 'MDM (kVA)', 'PDM (kVA)', 'PRDM (kVA)', 'RDM (kVA)', 'RH (F)', 'THD (Amp) (Bph)', 'THD (Amp) (Rph)', 'THD (Amp) (Yph)', 'THD (Vll) (Bph)', 'THD (Vll) (Rph)', 'THD (Vll) (Yph)', 'Vll (Avg)', and 'Vln (Avg)'. The 'Selected Parameters' list on the right contains: 'Amp (Avg)', 'Frequency', 'kVA (Total)', 'kVAh (Imp)', 'kVAR (Total)', 'kVARh (Imp-I)', 'kW (Total)', 'kWh (Imp)', 'THD (Amp) (Bph)', 'THD (Amp) (Rph)', 'THD (Amp) (Yph)', 'THD (Vll) (Bph)', 'THD (Vll) (Rph)', 'THD (Vll) (Yph)', 'Vll (Avg)', and 'Vln (Avg)'. There are 'Add' and 'Remove' buttons between the lists. At the bottom, there are 'Save' and 'Cancel' buttons.

SAMPLE REPORTS


REPORTS

PERIODIC REPORT


<div><div>Company Logo</div><div>Energy Management System</div><div>Company Name</div></div>											
Hourly Report											
Period		07-May-2016									
Generated On		03-Sep-2017									
Generated By		Administrator									
S/no	Device Name	Parameter Name	2016-05-07 00:00:00-2016-05-07 01:00:00	2016-05-07 01:00:00-2016-05-07 02:00:00	2016-05-07 02:00:00-2016-05-07 03:00:00	2016-05-07 03:00:00-2016-05-07 04:00:00	2016-05-07 04:00:00-2016-05-07 05:00:00	2016-05-07 05:00:00-2016-05-07 06:00:00	2016-05-07 06:00:00-2016-05-07 07:00:00	2016-05-07 07:00:00-2016-05-07 08:00:00	2016-05-07 08:00:00-2016-05-07 09:00:00
1	Device1	kVA (Total)	0.93	0.96	0.93	1.69	1.5	1.35	1.69	1.5	1.35
2	Device1	kW (Total)	0.92	0.96	0.93	1.57	1.38	1.23	1.57	1.38	1.23
3	Device1	kVAR (Total)	-0.03	-0.02	-0.02	-0.62	-0.59	-0.57	-0.62	-0.59	-0.57
4	Device1	PF (Avg)	0.999	0.999	0.999	0.929	0.918	0.905	0.929	0.918	0.905
5	Device1	VII (Avg)	420.09	420.05	422.87	419.9	419.9	422.83	419.9	419.9	422.83
6	Device1	VIn (Avg)	242.55	242.53	244.15	242.47	242.45	244.16	242.47	242.45	244.16
7	Device1	Amp (Avg)	1.52	1.57	1.54	2.35	2.11	1.94	2.35	2.11	1.94
8	Device1	Frequency	49.96	49.99	50.01	49.96	49.99	50.01	49.96	49.99	50.01
9	Device1	kWh (Imp)	0.9	0.9	0.5	1.5	1.3	0.7	1.5	1.3	0.7
10	Device2	kVA (Total)	3.98	3.86	4.22	0.53	0.54	0.53	0.53	0.54	0.53
11	Device2	kW (Total)	3.94	3.82	4.15	0.49	0.49	0.49	0.49	0.49	0.49
12	Device2	kVAR (Total)	0.59	0.53	0.73	-0.11	-0.06	-0.11	-0.11	-0.06	-0.11
13	Device2	PF (Avg)	0.989	0.99	0.985	0.935	0.923	0.938	0.935	0.923	0.938
14	Device2	VII (Avg)	420.25	420.24	423.04	420.01	419.93	422.98	420.01	419.93	422.98
15	Device2	VIn (Avg)	242.65	242.6	244.23	242.5	242.46	244.19	242.5	242.46	244.19
16	Device2	Amp (Avg)	5.5	5.33	5.8	0.87	0.88	0.88	0.87	0.88	0.88
17	Device2	Frequency	49.96	49.99	50.01	49.96	49.99	50.01	49.96	49.99	50.01
18	Device2	kVAh (Imp)	3.7	3.8	2.3	0.6	0.7	0.3	0.6	0.7	0.3
19	Device2	kWh (Imp)	3.6	3.8	2.3	0.5	0.4	0.3	0.5	0.4	0.3
20	Device2	kVARh (Imp-I)	0.5	0.4	0.3	6026.3	3013	3012.9	6026.3	3013	3012.9
21	Device3	kVA (Total)	1.44	1.64	1.6	0.25	0.25	0.25	0.25	0.25	0.25
22	Device3	kW (Total)	1.4	1.61	1.56	0.23	0.23	0.24	0.23	0.23	0.24

REPORTS

DASHBOARDS



Sino	Device Name	Parameter Name	2016-05-07 00:00:00-2016-05-07 01:00:00	2016-05-07 01:00:00-2016-05-07 02:00:00	2016-05-07 02:00:00-2016-05-07 03:00:00	2016-05-07 03:00:00-2016-05-07 04:00:00	2016-05-07 04:00:00-2016-05-07 05:00:00
1	Device1	kVA (Total)	0.93	0.96	0.93	0.93	0.96
2	Device1	kW (Total)	0.92	0.96	0.93	0.92	0.96
3	Device1	kVAR (Total)	-0.03	-0.02	-0.02	-0.03	-0.02
4	Device1	PF (Avg)	0.999	0.999	0.999	0.999	0.999
5	Device1	Vll (Avg)	420.09	420.05	422.87	420.09	420.05
6	Device1	Vln (Avg)	242.55	242.53	244.15	242.55	242.53
7	Device1	Amp (Avg)	1.52	1.57	1.54	1.52	1.57
8	Device1	Frequency	49.96	49.99	50.01	49.96	49.99
9	Device1	kWh (Imp)	120.6	118.5	114.2	103.6	100.9
10	Device2	kVA (Total)	3.98	3.86	4.22	3.98	3.86
11	Device2	kW (Total)	3.94	3.82	4.15	3.94	3.82
12	Device2	kVAR (Total)	0.59	0.53	0.73	0.59	0.53
13	Device2	PF (Avg)	0.989	0.99	0.985	0.989	0.99
14	Device2	Vll (Avg)	420.25	420.24	423.04	420.25	420.24
15	Device2	Vln (Avg)	242.65	242.6	244.23	242.65	242.6



	Today	Yesterday	Over/Under
EB			
Incomer-1	1200.0	1240.0	▼
Incomer-2	1150.0	1180.0	▼
Transformer-1	1170.0	1220.0	▼
Transformer-2	1120.0	1165.0	▼
Total	2350.0	2420.0	▼
DG			
DG-1	720.0	744.0	▼
DG-2	690.0	590.0	▲
Total	1410.0	1334.0	▲
UPS			
UPS-1	900.0	930.0	▼
UPS-2	862.5	837.8	▲
UPS-3	877.5	915.0	▼
Total	2640.0	2682.8	▼
Lighting			
Area-1	443.8	448.1	▼
Area-2	190.2	140.8	▲
Area-3	380.4	320.1	▲
Area-4	126.8	128.0	▼
Area-5	253.6	256.1	▼
Area-6	507.2	512.1	▼
Total	1902.0	1805.3	▲
HVAC			
Chiller-1	570.6	576.2	▼
Chiller-2	443.8	390.5	▲
Chiller-3	507.2	512.1	▼
Total	1521.6	1478.8	▲
Others			
Others-1	285.3	288.1	▼
Others-2	824.2	832.2	▼
Others-3	760.8	768.2	▼
Others-4	380.4	384.1	▼
Others-5	240.9	243.3	▼
Total	2491.6	2515.9	▼

REPORTS

INTEGRATED REPORT

Company Logo		Energy Management System			
Company Name					
Integrated Params Report					
Period		07-May-2016			
Generated On		03-Sep-2017			
Generated By		Administrator			
Sino	Device Name	Parameter Name	Initial Reading	Final Reading	Integrated Value
1	Device1	kWh (Imp)	41203.6	41205.9	2.3
2	Device2	kVAh (Imp)	71902.7	71912.5	9.8
3	Device2	kWh (Imp)	70279.9	70289.6	9.7
4	Device2	kVARh (Imp-I)	-176.2	-175	1.2
5	Device3	kVAh (Imp)	46652.8	46656.6	3.8
6	Device3	kWh (Imp)	43861.5	43865.2	3.7
7	Device3	kVARh (Imp-I)	-511.7	-511.7	0
8	Device4	kVAh (Imp)	53304.7	53308.5	3.8
9	Device4	kWh (Imp)	47948.7	47952.2	3.5
10	Device4	kVARh (Imp-I)	-513	-513	0
11	Device5	kVAh (Imp)	47916.8	47918.4	1.6
12	Device5	kWh (Imp)	43019.7	43020.9	1.2
13	Device5	kVARh (Imp-I)	3013.3	3014.9	1.6
14	Device6	kVAh (Imp)	85690.9	85691.5	0.6
15	Device6	kWh (Imp)	81952.8	81953.3	0.5
16	Device6	kVARh (Imp-I)	-1026.6	-1026.6	0
17	Device7	kVAh (Imp)	337.2	337.2	0
18	Device7	kWh (Imp)	270.1	270.1	0
19	Device7	kVARh (Imp-I)	198.8	198.8	0
20	Device8	kVAh (Imp)	36965.8	36967.3	1.5
21	Device8	kWh (Imp)	33849.7	33851	1.3
22	Device8	kVARh (Imp-I)	4535.8	4536.6	0.8

DAILY REPORT

Company Logo		Energy Management System										
Company Name												
Daily Report												
Period		07-May-2016										
Generated On		03-Sep-2017										
Generated By		Administrator										
Sino	Device Name	kVA (Total)	kW (Total)	kVAR (Total)	PF (Avg)	VII (Avg)	VIn (Avg)	Amp (Avg)	Frequency	kWh (Imp)	kVAh (Imp)	kVARh (Imp-I
1	Device1	0.94	0.94	-0.02	0.999	420.72	242.92	1.54	49.98	2.3	-	-
2	Device2	3.99	3.94	0.59	0.989	420.9	243	5.49	49.98	9.7	9.8	1.2
3	Device3	1.56	1.52	-0.3	0.978	-	-	2.16	49.98	3.7	3.8	0
4	Device4	1.54	1.41	-0.6	0.919	420.59	242.86	2.16	49.98	3.5	3.8	0
5	Device5	0.53	0.49	-0.09	0.931	420.68	242.88	0.88	49.98	1.2	1.6	12052.2
6	Device6	0.25	0.24	0.09	0.932	420.85	243.01	0.35	49.98	0.5	0.6	0
13	Device7	0.63	0.55	0.3	0.876	420.74	242.97	0.87	49.98	1.3	1.5	0.8
14	Device8	0.46	0.44	0.13	0.957	420.97	243.04	0.62	49.98	1.1	1.1	0
16	Device9	0.83	0.75	0.34	0.908	421.2	243.19	1.2	49.98	1.8	-	-
17	Device10	1.65	0.99	1.32	0.601	420.98	243.05	2.28	49.99	2.5	4.1	3.2
18	Device11	0.95	0.85	0.4	0.885	421.32	243.25	1.33	49.98	2.1	2.3	1
20	Device13	0.86	0.85	-0.09	0.988	410.29	236.89	1.27	49.98	2.1	2.2	2214.1
21	Device14	0	0	0	0	410.22	236.85	0	49.98	0	0	0
22	Device15	10.71	10.06	3.69	0.939	410.04	236.73	15.09	49.98	24.7	26.3	9
23	Device16	0	0	0	0	410.06	236.76	0	49.99	0	0	0
25	Device18	0	0	0	0	410.1	236.8	0	50.02	0	0	0
26	Device19	0.14	0.1	0.04	0.855	410.34	236.92	0.22	49.98	0.2	0.3	0
27	Device20	0.47	0.42	-0.2	0.901	421.11	243.14	0.65	49.98	1	1.1	47105
31	Device24	25.13	15.89	19.34	0.616	420.58	242.9	34.55	49.99	39.9	62.9	48
33	Device26	28.13	27.95	2.31	0.98	420.23	242.66	38.79	49.98	56.5	56.7	3.7
35	Device28	49.13	28.48	39.86	0.574	419.91	242.49	67.59	49.98	68.8	119	96.7
37	Device30	12.03	10.95	4.55	0.874	420.2	242.65	16.56	49.98	27	29.7	11.2

REPORTS

MIN MAX REPORT

Company Logo		Energy Management System				
		Company Name				
Min Max Report						
Period		07-May-2016 To 08-May-2016				
Generated On		03-Sep-2017				
Generated By		Administrator				
Sino	Device Name	Parameter Name	Min Occurance Time	Min	Max Occurance Time	Max
1	Device1	kVA (Total)	2016-05-07 14:32:00	0.85	2016-05-07 15:39:30	1.03
2	Device1	kW (Total)	2016-05-07 14:32:00	0.85	2016-05-07 15:51:40	1.04
3	Device1	kVAR (Total)	2016-05-07 15:54:30	-0.12	2016-05-07 15:15:00	0.07
4	Device1	PF (Avg)	2016-05-07 14:54:30	0.993	2016-05-07 14:06:00	1
5	Device1	VII (Avg)	2016-05-07 14:54:00	414.6	2016-05-07 16:28:00	427.17
6	Device1	VIn (Avg)	2016-05-07 14:54:00	239.4	2016-05-07 16:28:00	246.51
7	Device1	Amp (Avg)	2016-05-07 14:32:00	1.37	2016-05-07 14:17:00	1.69
8	Device1	Frequency	2016-05-07 14:27:30	49.89	2016-05-07 16:33:30	50.1
9	Device1	kWh (Imp)	2016-05-07 14:06:00	41203.6	2016-05-07 16:28:00	41205.9
10	Device2	kVA (Total)	2016-05-07 15:10:00	3.61	2016-05-07 16:14:00	4.59
11	Device2	kW (Total)	2016-05-07 15:35:00	3.58	2016-05-07 16:14:00	4.5
12	Device2	kVAR (Total)	2016-05-07 15:12:30	0.35	2016-05-07 16:19:00	0.99
13	Device2	PF (Avg)	2016-05-07 16:11:30	0.977	2016-05-07 15:01:30	1
14	Device2	VII (Avg)	2016-05-07 15:02:00	414.79	2016-05-07 16:31:00	427.2
15	Device2	VIn (Avg)	2016-05-07 15:02:00	239.53	2016-05-07 16:31:00	246.58
16	Device2	Amp (Avg)	2016-05-07 15:35:00	4.93	2016-05-07 16:14:00	6.36
17	Device2	Frequency	2016-05-07 14:27:00	49.89	2016-05-07 16:05:30	50.09
18	Device2	kVAh (Imp)	2016-05-07 14:06:00	71902.7	2016-05-07 16:32:00	71912.5
19	Device2	kWh (Imp)	2016-05-07 14:06:00	70279.9	2016-05-07 16:33:00	70289.6
20	Device2	kVARh (Imp-I)	2016-05-07 14:06:00	-176.2	2016-05-07 16:21:00	-175
21	Device3	kVA (Total)	2016-05-07 14:14:00	1.28	2016-05-07 15:38:30	3.54
22	Device3	kW (Total)	2016-05-07 14:14:00	1.24	2016-05-07 15:39:30	3.54

ZONE WISE REPORT

Company Logo		Energy Management System			
		Company Name			
Zone Wise Report					
Period		07-May-2016 To 07-May-2016			
Generated On		03-Sep-2017			
Generated By		Administrator			
Sino	Device Name	Parameter Name	Shift-1-{2016-05-07 07:00:00-2016-05-07 15:00:00}	Shift-2-{2016-05-07 15:00:00-2016-05-07 22:00:00}	Shift-3-{2016-05-07 22:00:00-2016-05-08 07:00:00}
1	Device1	kVA (Total)	0.93	0.95	1.69
2	Device1	kW (Total)	0.92	0.95	1.57
3	Device1	kVAR (Total)	-0.03	-0.02	-0.62
4	Device1	PF (Avg)	0.999	0.999	0.929
5	Device1	VII (Avg)	420.09	421.07	419.9
6	Device1	VIn (Avg)	242.55	243.11	242.47
7	Device1	Amp (Avg)	1.52	1.55	2.35
8	Device1	Frequency	49.96	50	49.96
9	Device1	kWh (Imp)	0.9	1.4	1.5
10	Device2	kVA (Total)	3.98	3.99	0.53
11	Device2	kW (Total)	3.94	3.94	0.49
12	Device2	kVAR (Total)	0.59	0.6	-0.11
13	Device2	PF (Avg)	0.989	0.988	0.935
14	Device2	VII (Avg)	420.25	421.25	420.01
15	Device2	VIn (Avg)	242.65	243.19	242.5
16	Device2	Amp (Avg)	5.5	5.49	0.87
17	Device2	Frequency	49.96	50	49.96
18	Device2	kVAh (Imp)	3.7	6.1	0.6
19	Device2	kWh (Imp)	3.6	6.1	0.5
20	Device2	kVARh (Imp-I)	0.5	0.7	6026.3
21	Device3	kVA (Total)	1.44	1.62	0.25
22	Device3	kW (Total)	1.4	1.59	0.23

REPORTS

WEEKLY, MONTHLY REPORT

Company Logo		Energy Management System													
		Company Name													
Monthly Report															
Period		May-2016													
Generated On		03-Sep-2017													
Generated By		Administrator													
Slno	Device Name	Parameter Name	2016-05-01	2016-05-02 00:00:00	2016-05-03 00:00:00	2016-05-04 00:00:00	2016-05-05 00:00:00	2016-05-06 00:00:00	2016-05-07 00:00:00	2016-05-08 00:00:00	2016-05-09 00:00:00	2016-05-10 00:00:00	2016-05-11 00:00:00	2016-05-12 00:00:00	2016-05-13 00:00:00
1	Device1	kVA (Total)	1.54	0.25	0.46	0.83	0.86	0.14	0.94	5.41	1.9	0.46	0.14	1.54	0.94
2	Device1	kW (Total)	1.41	0.24	0.44	0.75	0.85	0.1	0.94	2.5	1.83	0.44	0.1	1.41	0.94
3	Device1	kVAR (Total)	-0.6	0.09	0.13	0.34	-0.09	0.04	-0.02	3.1	0.51	0.13	0.04	-0.6	-0.02
4	Device1	PF (Avg)	0.919	0.932	0.957	0.908	0.988	0.855	0.999	0.493	0.963	0.957	0.855	0.919	0.999
5	Device1	Vll (Avg)	420.59	420.85	420.97	421.2	410.29	410.34	420.72	420.36	411.73	420.97	410.34	420.59	420.72
6	Device1	Vln (Avg)	242.86	243.01	243.04	243.19	236.89	236.92	242.92	242.69	237.75	243.04	236.92	242.86	242.92
7	Device1	Amp (Avg)	2.16	0.35	0.62	1.2	1.27	0.22	1.54	7.57	2.7	0.62	0.22	2.16	1.54
8	Device1	Frequency	49.98	49.98	49.98	49.98	49.98	49.98	49.98	49.98	49.97	49.98	49.98	49.98	49.98
9	Device1	kWh (Imp)	3.5	0.5	1.1	1.8	2.1	0.2	2.3	6.4	0.6	1.1	0.2	3.5	2.3
10	Device2	kVA (Total)	0.53	0.63	1.65	0.95	10.71	0.47	3.99	4.17	6.8	1.65	0.47	0.53	3.99
11	Device2	kW (Total)	0.49	0.55	0.99	0.85	10.06	0.42	3.94	2.45	6.6	0.99	0.42	0.49	3.94
12	Device2	kVAR (Total)	-0.09	0.3	1.32	0.4	3.69	-0.2	0.59	3.28	1.61	1.32	-0.2	-0.09	0.59
13	Device2	PF (Avg)	0.931	0.876	0.601	0.885	0.939	0.901	0.989	0.598	0.971	0.601	0.901	0.931	0.989
14	Device2	Vll (Avg)	420.68	420.74	420.98	421.32	410.04	421.11	420.9	420.48	411.66	420.98	421.11	420.68	420.9
15	Device2	Vln (Avg)	242.88	242.97	243.05	243.25	236.73	243.14	243	242.79	237.66	243.05	243.14	242.88	243
16	Device2	Amp (Avg)	0.88	0.87	2.28	1.33	15.09	0.65	5.49	5.81	14.76	2.28	0.65	0.88	5.49
17	Device2	Frequency	49.98	49.98	49.99	49.98	49.98	49.98	49.98	49.98	49.98	49.99	49.98	49.98	49.98

REPORTS

YEARLY REPORT

Company Logo		Energy Management System																
		Company Name																
Yearly Report																		
Period		2016																
Generated On		03-Sep-2017																
Generated By		Administrator																
S/no	Device Name	Parameter Name	Jan-2016	Feb-2016	Mar-2016	Apr-2016	May-2016	Jun-2016	Jul-2016	Aug-2016	Sep-2016	Oct-2016	Nov-2016	Dec-2016	Min	Max	Avg	Total
1	Device1	kVA (Total)	1.52	0.83	0.8	0.92	0.94	0.77	1.31	1.54	2.9	3.26	0.46	3.21	0.8	0.94	0.89	2.66
2	Device1	kW (Total)	1.38	0.75	0.8	0.92	0.94	0.55	1.2	1.41	2.9	3.24	0.44	2.97	0.8	0.94	0.89	2.66
3	Device1	kVAR (Total)	0.62	0.34	0.04	-0.06	-0.02	0.54	-0.52	-0.6	0.14	-0.04	0.13	1.2	-0.06	0.04	-0.01	-0.04
4	Device1	PF (Avg)	0.919	0.908	0.999	0.994	0.999	0.717	0.899	0.919	0.999	0.944	0.957	0.928	0.994	0.999	0.997	2.992
5	Device1	VII (Avg)	420.79	421.2	412.8	420.25	420.72	412.64	420.08	420.59	419.08	420.4	420.97	418.93	412.8	420.72	417.92	1253.77
6	Device1	VIn (Avg)	242.95	243.19	238.34	242.64	242.92	238.26	242.54	242.86	241.96	242.71	243.04	241.88	238.34	242.92	241.3	723.9
7	Device1	Amp (Avg)	2.14	1.2	1.34	1.46	1.54	1.12	1.84	2.16	4.11	4.56	0.62	4.43	1.34	1.54	1.45	4.34
8	Device1	Frequency	49.96	49.98	49.99	49.96	49.98	49.99	49.96	49.98	49.99	49.96	49.98	49.98	49.96	49.99	49.98	149.93
9	Device1	kWh (Imp)	56.8	60.34	61.4	61.2	62.8	59.6	63.2	64.6	68.9	69.2	61.2	68.3	59.6	69.2	64.4	757.54
10	Device2	kVA (Total)	0.93	0.95	1.06	5.58	3.99	0.89	1.14	0.53	1.68	1.74	1.65	1.31	1.06	5.58	3.54	10.63
11	Device2	kW (Total)	0.84	0.85	1.01	5.53	3.94	0.87	1.03	0.49	0.77	1.02	0.99	1.21	1.01	5.53	3.49	10.48
12	Device2	kVAR (Total)	0.39	0.4	0.32	0.68	0.59	0.16	0.04	-0.09	1.49	1.39	1.32	0.45	0.32	0.68	0.53	1.59
13	Device2	PF (Avg)	0.887	0.885	0.954	0.992	0.989	0.982	0.85	0.931	0.456	0.584	0.601	0.858	0.954	0.992	0.978	2.935
14	Device2	VII (Avg)	420.85	421.32	412.91	420.38	420.9	418.85	420.12	420.68	418.64	420.5	420.98	418.94	412.91	420.9	418.06	1254.19
15	Device2	VIn (Avg)	242.99	243.25	238.41	242.72	243	241.83	242.58	242.88	241.7	242.78	243.05	241.9	238.41	243	241.38	724.13
16	Device2	Amp (Avg)	1.31	1.33	1.48	7.69	5.49	1.24	1.67	0.88	2.32	2.4	2.28	1.86	1.48	7.69	4.89	14.66
17	Device2	Frequency	49.96	49.98	49.99	49.96	49.98	49.98	49.96	49.98	49.98	49.96	49.99	49.98	49.96	49.99	49.98	149.93

**SOFTWARE WILL BE CUSTOMISED
AS PER CUSTOMER NEEDS**

CLIENTELE



THANK YOU